

GOVERNMENT OF TRIPURA
OFFICE OF THE ASSISTANT ENGINEER
PWD(DWS), SUB-DIVISION, BADHARGHAT
AGARTALA, TRIPURA(WEST)

File No.2(14)/AE/DWS/SD/BDGT/2026-27/.....314.

Dated:- 27/08/2026


TO WHOM IT MAY CONCERN

This is to certify that the surroundings of Surjyamaninagar H.S. School, Sadar, West Tripura are very Hygienic and drinking water from existing source is safe for health in all respect.

Authority of Surjyamaninagar H.S. School are maintaining cleanness regularly and not likely to spread any kind of disease.

Attested

02.09.26
(LINA DEBBARMA)
Principal,
Surjyamaninagar H.S. School,
Sadar, West Tripura.


27.08.26
(Er. Bikram Mallik)
S.D.O
DWS Sub-Division, Badharghat
Agartala, Tripura(West)
E-mail: aedwsbadharghat@gmail.com

State Level Water Testing Laboratory

PWD(DWS), Government of Tripura
P.N. Complex,
Agartala - 799006
Mobile : 9402120089,
Website : www.dws.tripura.gov.in



TC-7350

TEST REPORT

Name & Address of the customer

Principal, Water Sample from
Surjyamaninagar H/S School. Sadar
West Tripura., Tripura

Report No : SLWTL/2017/6635
Report Date : 13-08-2026
Sample ID : D85YP9G0T1
Date of Receipt of Sample : 10/08/2026, 12.30 pm
Date(s) of Performance : 12/08/2026
Ref. No. & Date : No.F.1(13)/HM-SMN/HS/1995/184 Dte-07/08/2026
ULR No : TC735025000013775F

We hereby certify that the following sample submitted to the laboratory has been analyzed with the following results :

1.	Description of Sample (As declared by customer)	: Drinking Water
2.	Volume of Sample Received	: 500 ml
3.	Sample Mark (if any, given by the customer)	: NA
4.	Date of Sampling by the Customer	: 10/08/2026
5.	Source & Place of Sampling	: Water Sample from Surjyamaninagar H/S School. Sadar West Tripura.
6.	Environmental conditions during sampling	: NA
7.	Sampling Plan & Procedures used	: NA

Report
Prepared by

Signature

Name

Designation

: Ratan Shil

: Technical Manager

For State Level Water Testing Laboratory

Signature

Name

Designation

: Sujoy Paul

: Quality Manager

Authorized Signatory

- The results relate only to the item(s) tested.
- This Test Report shall not be reproduced except in full, without the permission of State Level Water Testing Laboratory, PWD(DWS)
- The reserved part of sample(s) shall be retained for 15 days from the date of Completion of Test.

Contact Person : Dr Sujoy Paul,

Quality Manager, State Level Water Testing Laboratory

Mobile : 9402120089, Email : s.manna.paul@gmail.com, Website : www.dws.tripura.gov.in

State Level Water Testing Laboratory

PWD(DWS), Government of Tripura
P.N. Complex,
Agartala - 799006
Mobile : 9402120089,
Website : www.dws.tripura.gov.in



TC-7360

Report No : SLWTL/2017/6635
Sample ID : D85YP9G0T1

Analysis of Result

SN	Characteristic	Acceptable Limit (as per BIS 10500:2012)	Permissible Limit (as per BIS 10500:2012)	Method of Test	Results
1	Turbidity in N.T.U	1	5	APHA 24th Edition 2130 B	0.65
2	pH value at 25°C	6.5-8.5	No Relaxation	APHA 24th Edition 4500-H+ B	7.20
3	Iron (as Fe) in mg/l	1.0	No Relaxation	APHA 24th Edition 3500-Fe B	0.390
4	Total Dissolved Solids in mg/l	500	2000	APHA 24th Edition 2540 C	76.7

EDL - Below Detection Level for Fluoride - <0.2 mg/l, Arsenic - <0.009 mg/l, Iron - <0.1 mg/l, Magnesium - <2 mg/l, Manganese - <0.01 mg/l

Report Prepared by

Signature 
Name : Ratan Shil
Designation : Technical Manager

For State Level Water Testing Laboratory

Signature 
Name : Sujoy Paul
Designation : Quality Manager
Authorized Signatory

-: End Of Report :-

Contact Person : Dr Sujoy Paul

Quality Manager, State Level Water Testing Laboratory,

Mobile : 9402120089, Email : s.manna.paul@gmail.com, Website : www.dws.tripura.gov.in